

APPENDIX 12.2

Clauses for a Prior Consent Notice under Section 61 of the Control of Pollution Act 1974

1. That the hours of operation of activities related to general construction works be restricted to 0800-1800 hours Monday to Saturday (excluding bank holidays) except otherwise than with the prior approval of the Environmental Health Department of Devon County Council.
2. That the hours of piling operations be restricted to 0800-1800 hours Monday to Friday and 0900-1700 hours Saturdays (excluding bank holidays)
3. That the maximum noise levels emanating from any activities related to construction or demolition work shall not exceed 70 dBL_{Aeq} (1hour) with a maximum noise level of 80 dBL_{A01} when measured at a point three metres from the façade of the nearest residential building.
4. That all appropriate noise reduction measures be taken to minimise disturbance during the work including the use of acoustic shrouds and a suitable non-metallic dolly on the piling apparatus (unless ground conditions require otherwise in which case the prior approval of the Environmental Health Department of Devon County Council shall be obtained for use of an alternative dolly).
5. That the maximum continuous peak vibrations velocity shall not exceed 4mm/sec (measured in accordance with ISO/DIS 4866) and that all piling work shall have a peak vibration velocity of 6mm/sec when measured at the point specified in 3 above.
6. That the work shall not involve the use of piling equipment.
7. That all standing plant such as compressors, generators etc. shall be housed in acoustic enclosures and that all portable plant and equipment shall be fitted with acoustic insulation and that the said plant & equipment shall only be operated with the enclosures/insulation intact.
8. That no work shall be carried on during the periods *December to *December **** inclusive or at all on 1 January ****.
9. That all temporary traffic lights be connected to available street lighting points and that no mobile generators be used on site without the prior approval of the Environmental Health Department of Devon County Council
10. That all work complies with the requirements of British Standard BS5228 Parts 1-4.